



We help ideas meet the real world

Compliance Statement

No. 2016-450

Screened Channel, Class E_A

Company

Excel
Excel House
Junction Six Industrial Park
Electric Avenue
Birmingham, B6 7JJ
United Kingdom

Channel Identification (4 connector model)

Horizontal cable:

100-196 Excel Category 6_A Screened F/FTP "S" Foil Cable LS0H

Terminal Cord and Patch Cord:

100-154 Excel Category 6_A Screened F/FTP LS0H Patch Lead, Booted, 5m, Grey
100-148 Excel Category 6_A Screened F/FTP LS0H Patch Lead, Booted, 1m, Grey

Consolidation Point Cable and Equipment Cord:

100-133 Excel Category 6_A Solid Core (F/FTP) screened harness/switch link leads – 30m
(cut to length and jack added)

Telecommunication Outlet and Patch Panel Jacks:

100-181 Excel Category 6_A Low Profile Screened Keystone Jack - Toolless

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

Technical report

DELTA-T212853-02, DANAK-19/16608

EC Cabling product ID


5347

CS valid until

1 August 2017

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 18 August 2016


Lars Lindskov Pedersen
Test Manager


Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable

